

ADDENDUM NUMBER 2
DATED 5/6/2025

Morris Mill and Overlay Project
Project TB-90820
MnDOT 25-154128
Architect: District 4.

1.01 NOTICE TO RESPONDERS

- A. This Addendum is issued pursuant to the Instructions to Responders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. An additional mandatory pre-bid meeting has been scheduled for May 13th, 2025, at 11:00 am. If you attended the previous pre-bid meeting, you have fulfilled the attendance requirement and are not required to attend.
- C. The date for receipt of bids is changed to the following, May 22, 2025
 - 1. Revised Bid Date: May 22, 2025.

1.02 ATTACHMENTS

- A. This Addendum includes the following attached Documents and Specification Sections:
 - 1. Document – Pre-bid Meeting #1 Attendance Sheet, dated April 30, 2025, new.
 - 2. Document – Questions and responses from Pre-bid Meeting #1, new.

END OF ADDENDUM ____

Meeting Attendance Record

MEETING FOR: Pre-Bid Meeting

DATE: 04/30/2025

PROJECT: Morris Mill and Overlay Project

PROJECT NUMBER: 25-154128, TB-90820

NAME: (Please Print Clearly)	REPRESENTING:	TELEPHONE	E-MAIL
Rick Bolin	MnDOT Bldg. Services	651-802-8098	richard.bolin@state.mn.us
Greg Graves	See Riley Construction	320-287-1916	greggraves@rileyconstruction.com
Math Tolifson	MnDOT Morris Cons.	320-815-2494	Matthew.Tolifson@State.mn.us
Joel Ullring	MnDOT OMRR	651-266-5432	joel.ullring@state.mn.us
Joe Riley	Joe Riley Const	282-1901 320-287	J Riley Riley Construction - Com
Justin Knopf	MnDOT D4	218-849-8297	Justin.Knopf@state.mn.us
Nick Elijah	MnDOT D4	218-849-3578	nicholas.elijah@state.mn.us
Dan Riehart	MnDOT D4	218-850-0912	Daniel.Riehart@State.mn.us
Chad Schwarz	MnDOT D4	320-349-0382	chad.schwarz@State.mn.us
Justin Le Clair	MnDOT D4	218-849-2570	Justin.LeClair@state.mn.us

Morris HQ Mill & Overlay Questions and Responses

1. Question - Division 32 is referenced in the General Contents and is not found in bid documents.
 - a. Division 32 can be found in the Addenda #1 documents.
2. What type of rebar, uncoated or epoxy coated?
 - a. Epoxy coated rebar is requested.
3. Stockpiling and handling of materials – Excavated and milled materials will remain on site and will be stockpiled approximately 200 yds south of the project area. Contractor will be responsible for daily relocation of removed materials to the stockpile locations with necessary equipment as well as SWPP measures until substantial completion.